


SAMPLE TYPE CODE S - Routine Sample P - Repeat sample (at original tap) E - Enforcement (chain of custody) U - Upstream repeat D - Downstream repeat X - Other Repeat W - Untreated V - Invalidated by Lab C - Construction / Special	ANALYTICAL LABORATORIES, INC. ID00020 1804 N. 33rd Street Boise, Idaho 83703 1-800-574-5773 1-208-342-5515 www.analyticallaboratories.com			
	X Public Water Supply		Private Water Supply	
			Other _____	
				PDF Only
	NAME OF WATER SYSTEM SUMMERWIND		COUNTY CANYON	PWS 3140220
	REPORT RESULTS TO:			

TOM MEHIEL VALLEY HYDRO INC 1904 E BEECH ST CALDWELL, ID 83605	DATE RECEIVED 7/20/2018
	TIME RECEIVED 11:05
	DATE ANALYZED 7/20/2018
	TIME ANALYZED 13:45

SEND ADDITIONAL COPIES TO: SWDH; summerwind hoa 1500 w. bannock boise, id 83702	IF RETEST, ORIGINAL SAMPLE DATE
e-mail: tom@valleyhydro.com	
Phone (208) 941-5989 Ext Fax	CHILLED 10 C <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO

COLLECTED BY: TOM		TRANSPORTED BY: TOM				
SAMPLE TYPE	COLLECTION DATE/TIME	Sampling Location	CI res	TOTAL COLIFORMS SM 9223	E. COLI SM 9223	HPC SM 9215

S	7/19/2018 11:00	LAB# 1834514 22900 CIRRUS VIEW	0.25	ABSENCE	ABSENCE	
---	--------------------	--------------------------------------	------	---------	---------	--

REMARKS:	ANALYST: TJR DATE PRINTED: 7/21/2018
ANALYTICAL METHODS <u>Total Coliforms</u> SM 9222 Membrane Filter Technique, Parts 909 and 909A, Standard Methods... 16th ed., 1985 SM 9221 Multiple Tube Fermentation, Parts 908 and 908A, and 908B, Standard Methods... 16th ed., 1985 SM 9223 MMO-MUG Test Per 40 CFR 141.21(f)(3)(IV) Reported as per 100 mL Records shall be retained and destroyed in accordance with IDAPA 58.01.08 and 40 CFR 141.33. In general, records shall not be retained beyond prescribed retention times.	<u>E. coli</u> MUG Test Per 141.214(x)(7) and 40 CFR 141.21(f)(6)(III) <u>HPC</u> Pour Plate, Part 907, Standard Methods... 16th ed., 1985 Reported as CFU/mL Analytical Laboratories, Inc.  7-24-18 Brian McGovern Date Laboratory Supervisor



Analytical Laboratories, Inc.

1804 N. 33rd Street
Boise, Idaho 83703
Phone (208) 342-5515
<http://www.analyticallaboratories.com>

Records shall be retained and destroyed in accordance with IDAPA 58.01.08 and 40 CFR 141.33.
In general, records shall not be retained beyond prescribed retention times.

Date Report Printed: 7/24/2018
CC: SWDH; summerwind hoa 1500 w. barnock boise, id 8
**Note: EPA Methods 504.1, 505, 515.4, 525.2, and 549.2 were performed by Analtek Labs (ATL).


LAB FEDERAL ID#	ID00020	LAB SAMPLE #:	1828647
DATE LAB REPORT SAMPLE	6/21/2018	DATE REPORTED BY LAB:	7/24/2018
COMPLIANCE SAMPLE:	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	REPLACEMENT SAMPLE	<input type="checkbox"/>
COLLECTION DATE:	6/21/2018	COLLECTION TIME:	11:25
SAMPLE TYPE:	<input type="checkbox"/> CO-confirmation <input checked="" type="checkbox"/> RT-routine	RP-repeat	<input type="checkbox"/>
	<input type="checkbox"/> DU-duplicate	SP-special	<input type="checkbox"/>
	<input type="checkbox"/> Other		
PWS#:	3140220	PWS NAME:	SUMMERWIND
SAMPLING POINT/LOCATION:	TAG #/FACILITY ID:		
SUMMERWIND WELL #2			
COLLECTOR'S NAME:	TOM	CONTACT PHONE #:	(208) 941-5989

PUBLIC DRINKING WATER SYSTEM SYNTHETIC ORGANIC CHEMICAL (SOC) ANALYSIS REPORT:

FRDS	Contaminant Name	Result*	Method	MDL	MDL*	Analysis Date	Analyst
2046	Carbortran	ND	EPA 531.2	40	2	7/17/2018	RG
2042	Hexachlorocyclopentadiene	ND	EPA 525.2	50	0.2	7/17/2018	ATL
2041	Dinoseb	ND	EPA 515.4	7	0.2	6/30/2018	ATL
2040	Picloram	ND	EPA 515.4	500	0.1	6/30/2018	ATL
2037	Simazine	ND	EPA 525.2	4.0	0.15	7/17/2018	ATL
2036	Oxamyl	ND	EPA 531.2	200	4	7/17/2018	RG
2035	Di(2-ethylhexyl)adipate	ND	EPA 525.2	400	0.2	7/17/2018	ATL
2034	Glyphosate	ND	EPA 547	700	10	6/25/2018	RG
2033	Endosulf	ND	EPA 548.1	100	10	6/29/2018	CG
2032	Diquat	ND	EPA 549.2	20	0.8	6/29/2018	ATL
2031	Dalapon	ND	EPA 515.4	200	1	6/30/2018	ATL
2020	Toxaphene	ND	EPA 505	3.0	0.1	7/5/2018	ATL
2015	Methoxychlor	ND	EPA 505	40.0	0.1	7/5/2018	ATL
2010	Lindane	ND	EPA 505	0.2	0.02	7/5/2018	ATL
2005	Endrin	ND	EPA 505	2.0	0.02	7/5/2018	ATL
	Chlordane	ND	EPA 505	2.0	0.1	7/5/2018	ATL
	EDB	ND	EPA 504.1	0.05	0.02	6/29/2018	ATL
	DBCP	ND	EPA 504.1	0.2	0.04	6/29/2018	ATL
	PCBs	ND	EPA 505	0.5	0.1	7/5/2018	ATL
	Pentachlorophenol	ND	EPA 515.4	1	0.04	6/30/2018	ATL
	Benzo(a)pyrene	ND	EPA 525.2	1.0	0.2	7/17/2018	ATL
	Di(2-ethylhexyl)phthalate	ND	EPA 525.2	6.0	0.6	7/17/2018	ATL
	Hexachlorobenzene	ND	EPA 525.2	1.0	0.2	7/17/2018	ATL
	2,4,5-TP	ND	EPA 515.4	50	0.2	6/30/2018	ATL
	2,4-D	ND	EPA 515.4	70	0.1	6/30/2018	ATL
	Heptachlor epoxide	ND	EPA 505	0.2	0.02	7/5/2018	ATL
	Heptachlor	ND	EPA 505	0.4	0.04	7/5/2018	ATL
	Alachlor	ND	EPA 525.2	2.0	0.4	7/17/2018	ATL
	Atrazine	ND	EPA 525.2	3.0	0.2	7/17/2018	ATL

*Reported in ug/L unless otherwise noted
ND = Not detected within sensitivity of instrument (MDL)

-- = No analysis performed
MDL = Method detection limit


Signature of Laboratory Supervisor
Date: 7-26-18

Client Manager: **Brian M. McGovern**

TOM MEHIEL
VALLEY HYDRO INC
1904 E BEECH ST
CALDWELL, ID, 83605



Analytical Laboratories, Inc.

1804 N. 33rd Street
Boise, Idaho 83703
Phone (208) 342-5515
<http://www.analyticallaboratories.com>

Records shall be retained and destroyed in accordance with IDAPA 58.01.08 and 40 CFR 141.33.
In general, records shall not be retained beyond prescribed retention times.

Date Report Printed: 7/24/2018

CC: SWDH; summerwind hca 1500 w. barnock boise, id 83702

**Note: EPA Methods 504.1, 505, 515.4, 525.2, and 549.2 were performed by Anatek Labs (ATL).

LAB FEDERAL ID#: ID000020	LAB SAMPLE #: 1828647
DATE LAB RECD SAMPLE: 6/21/2018	DATE REPORTED BY LAB: 7/24/2018
COMPLIANCE SAMPLE <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	REPLACEMENT SAMPLE <input type="checkbox"/>
COLLECTION DATE: 6/21/2018	COLLECTION TIME: 11:25 (24 hour clock)
SAMPLE TYPE: X RT-routine <input type="checkbox"/> CO-conformation <input type="checkbox"/> RP-repeat <input type="checkbox"/> DU-duplicate <input type="checkbox"/> SP-special <input type="checkbox"/> Other <input type="checkbox"/>	
PWS#: 3140220	PWS NAME: SUMMERWIND
SAMPLING POINT/LOCATION: SUMMERWIND WELL #2	TAG #/FACILITY ID:
COLLECTOR'S NAME: TOM	CONTACT PHONE: (208) 941-5989

PUBLIC DRINKING WATER SYSTEM VOLATILE ORGANIC CHEMICAL (VOC) ANALYSIS REPORT:

METHOD: ERA 524.2		ANALYSIS DATE: 6/25/2018		ANALYST: GY	
FRDS	Contaminant Name	Result	MCL*	MDL*	MDL*
2378	1,2,4-Trichlorobenzene	ND	70.0	0.5	
2380	cis-1,2-Dichloroethylene	ND	70.0	0.5	
2950	Trihalomethanes - Total	ND	80.0	0.5	
2941	Chloroform	ND		0.5	
2942	Bromoform	ND		0.5	
2943	Bromodichloromethane	ND		0.5	
2944	Dibromochloromethane	ND		0.5	
2955	Xylenes - Total	ND	10000	0.5	
2964	Dichloromethane	ND	5.0	0.5	
2969	p-Dichlorobenzene	ND	75.0	0.5	
2968	o-Dichlorobenzene	ND	600.0	0.5	
2976	Vinyl chloride	ND	2.0	0.5	
2977	1,1-Dichloroethylene	ND	7.0	0.5	
2979	trans-1,2-Dichloroethylene	ND	100.0	0.5	
2980	1,2-Dichloroethane	ND	5.0	0.5	
2981	1,1,1-Trichloroethane	ND	200.0	0.5	
2982	Carbon Tetrachloride	ND	5.0	0.5	
2983	1,2-Dichloropropane	ND	5.0	0.5	
2984	Trichloroethylene	ND	5.0	0.5	
2985	1,1,2-Trichloroethane	ND	200.0	0.5	
2987	Tetrachloroethylene	ND	5.0	0.5	
2989	Monochlorobenzene	ND	100.0	0.5	
2990	Benzene	ND	5.0	0.5	
2991	Toluene	ND	1000.0	0.5	
2992	Ethylbenzene	ND	700.0	0.5	
2996	Styrene	ND	100.0	0.5	

*Reported in ug/L unless otherwise noted
ND = Not detected within sensitivity of instrument (MDL) MDL = Method detection limit
--- = No analysis performed

TOM MEHIEL
VALLEY HYDRO INC
1904 E BEECH ST
CALDWELL, ID, 83605

Signature of Laboratory Supervisor
Client Manager: Brian M. McGovern
Date: 7-26-18



Analytical Laboratories, Inc.

1804 N. 33rd Street
Boise, Idaho 83703
Phone (208) 342-5515

PDF Only

Email: tom@valleyhydro.com

CC: SWDH; summerwind hoa 1500 w. bannock boise, id 83702


Note: EPA Methods 504.1, 505, 515.4, 525.2, and 549.2 were performed by Anatek Labs (ATL).

Lab Federal ID#: ID00020	Lab Sample 1928647
Date Lab Rec'd Sample: 6/21/2018	Date Reported by Lab: 7/24/2018
Compliance Sample: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Replacement Sample <input type="checkbox"/>
Collection Date: 6/21/2018	Time Collected: 11:25
Sample Type: <input type="checkbox"/> CO-confirmation <input type="checkbox"/> RP-repeat	<input type="checkbox"/> Other
<input checked="" type="checkbox"/> RT-routine <input type="checkbox"/> DU-duplicate	<input type="checkbox"/> SP-special
PWS #: 3140220	PWS Name: SUMMERWIND
Sampling Point/Location SUMMERWIND WELL #2	Tag # / Facility ID:
Collector's Name: TOM	Contact Phone #: (208) 941-5989

PUBLIC DRINKING WATER SYSTEM RADIOLOGICAL ANALYSIS REPORT

FRDS Number	CONTAMINANT	Result ug/L	Result pCi/L	MCL	Analysis Date	Analyst	Method
4002	Gross Alpha Activity (Includes Radium and Uranium)	ND	--	15 pCi/L			
4006	Uranium, Combined (Required if gross alpha exceeds 15 pCi/L, activity = 0.67 x concentration ug/L)	ND	ND	30	6/25/2018	JH	EPA 200.8
4000	Adjusted Gross Alpha (Subtract Uranium activity level from Gross Alpha Activity above)		--				
4020	Radium-226 (Required if Alpha activity is greater than 5pCi/L)		--	5 pCi/L			
4030	Radium-228		--	5 pCi/L			
4010	Total Measured Radium (add results of Ra-226 and Ra-228)		--				
4100	Beta/Photon Activity (Measure major isotopes if activity exceeds 50 pCi/L)		--				

ND = Not detected within sensitivity of instrument
-- = No analysis performed for this contaminant


 Lab Supervisor's Signature Date 7-26-18

Attn: TOM MEHIEL
 VALLEY HYDRO INC
 1904 E BEECH ST
 CALDWELL, ID 83605



Analytical Laboratories, Inc.

1804 N. 33rd Street
Boise, Idaho 83703
Phone (208) 342-5515

<http://www.analyticallaboratories.com>

Records shall be retained and destroyed in accordance with IDAPA 58.01.08 and 40 CFR 141.33.
In general, records shall not be retained beyond prescribed retention times.

Date Report Printed: 7/24/2018

CC: SWDH; summerwind hoa 1500 w. bannock boise, id 83702

**Note: EPA Methods 504.1, 505, 515.4, 525.2, and 549.2 were performed by Anatek Labs (ATL).

LAB FEDERAL ID#: ID00020	LAB SAMPLE #: 1828648
DATE LAB REC'D SAMPLE: 6/21/2018	DATE REPORTED BY LAB: 7/24/2018
COMPLIANCE SAMPLE <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	REPLACEMENT SAMPLE <input type="checkbox"/>
COLLECTION DATE: 6/21/2018	COLLECTION TIME: 12:00
SAMPLE TYPE: <input type="checkbox"/> CO-conformation <input type="checkbox"/> RP-repeat	
X RT-routine <input type="checkbox"/> DU-duplicate <input type="checkbox"/> SP-special <input type="checkbox"/> Other	
PWS#: 3140220	PWS NAME: SUMMERWIND
SAMPLING POINT/LOCATION: SUMMERWIND WELL #1	TAG #/FACILITY ID:
COLLECTOR'S NAME: TOM	CONTACT PHONE: (208) 941-5989

PUBLIC DRINKING WATER SYSTEM VOLATILE ORGANIC CHEMICAL (VOC) ANALYSIS REPORT:

METHOD: EPA 524.2	ANALYSIS DATE: 6/25/2018	ANALYST: GY		
FRDS	Contaminant Name	Result	MCL*	MDL*
2378	1,2,4-Trichlorobenzene	ND	70.0	0.5
2380	cis-1,2-Dichloroethylene	ND	70.0	0.5
2950	Trihalomethanes - Total	ND	80.0	0.5
2941	Chloroform	ND		0.5
2942	Bromoform	ND		0.5
2943	Bromodichloromethane	ND		0.5
2944	Dibromochloromethane	ND		0.5
2955	Xylenes - Total	ND	10000	0.5
2964	Dichloromethane	ND	5.0	0.5
2969	p-Dichlorobenzene	ND	75.0	0.5
2968	o-Dichlorobenzene	ND	600.0	0.5
2976	Vinyl chloride	ND	2.0	0.5
2977	1,1-Dichloroethylene	ND	7.0	0.5
FRDS	Contaminant Name	Result	MCL*	MDL*
2979	trans-1,2-Dichloroethylene	ND	100.0	0.5
2980	1,2-Dichloroethane	ND	5.0	0.5
2981	1,1,1-Trichloroethane	ND	200.0	0.5
2982	Carbon Tetrachloride	ND	5.0	0.5
2983	1,2-Dichloropropane	ND	5.0	0.5
2984	Trichloroethylene	ND	5.0	0.5
2985	1,1,2-Trichloroethane	ND	200.0	0.5
2987	Tetrachloroethylene	ND	5.0	0.5
2988	Monochlorobenzene	ND	100.0	0.5
2990	Benzene	ND	5.0	0.5
2991	Toluene	ND	1000.0	0.5
2992	Ethylbenzene	ND	700.0	0.5
2996	Styrene	ND	100.0	0.5

*Reported in ug/L unless otherwise noted
ND = Not detected within sensitivity of instrument(MDL) MDL = Method detection limit

--- = No analysis performed

TOM MEHIEL
VALLEY HYDRO INC
1904 E BEECH ST
CALDWELL, ID, 83605

Signature of Laboratory Supervisor
Date: 7-26-18
Client Manager: Brian M. McGovern



Analytical Laboratories, Inc.

1804 N. 33rd Street
Boise, Idaho 83703
Phone (208) 342-5515

<http://www.analyticallaboratories.com>

Records shall be retained and destroyed in accordance with IDAPA 58.01.08 and 40 CFR 141.33.
In general, records shall not be retained beyond prescribed retention times.


Date Report Printed: 7/24/2018
CC: SWDH; summerwind hoa 1500 w. bannock boise, id 8
**Note: EPA Methods 504.1, 505, 515.4, 525.2, and 549.2
were performed by Anatek Labs (ATL).

LAB FEDERAL ID#	ID00020	LAB SAMPLE #:	1828648
DATE/LAB RECEIVED SAMPLE:	6/21/2018	DATE REPORTED BY LAB:	7/24/2018
COMPLIANCE SAMPLE:	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	REPLACEMENT SAMPLE	<input type="checkbox"/>
COLLECTION DATE:	6/21/2018	COLLECTION TIME:	12:00
SAMPLE TYPE:	<input type="checkbox"/> CO-confirmation <input type="checkbox"/> DUPLICATE <input type="checkbox"/> RP-repeat <input type="checkbox"/> SP-special <input type="checkbox"/> Other		
PWS#:	3140220	PWS NAME:	SUMMERWIND
SAMPLING POINT/LOCATION:	TAG #/FACILITY ID:		
SUMMERWIND WELL #1			
COLLECTOR'S NAME:	TOM	CONTACT PHONE #:	(208) 941-5989

PUBLIC DRINKING WATER SYSTEM SYNTHETIC ORGANIC CHEMICAL (SOC) ANALYSIS REPORT:

FRDS	Contaminant Name	Result*	Method	MCL*	MDL*	Analysis Date	Analysis	FRDS	Contaminant Name	Result*	Method	MCL*	MDL*	Analysis Date	Analyst
2046	Carbofuran	ND	EPA 531.2	40	2	7/17/2018	RG	2959	Chlordane	ND	EPA 505	2.0	0.1	7/5/2018	ATL
2042	Hexachlorocyclopentadiene	ND	EPA 525.2	50	0.2	7/17/2018	ATL	2946	EDB	ND	EPA 504.1	0.05	0.02	6/29/2018	ATL
2041	Dinoseb	ND	EPA 515.4	7	0.2	6/30/2018	ATL	2931	DBCP	ND	EPA 504.1	0.2	0.04	6/29/2018	ATL
2040	Picloram	ND	EPA 515.4	500	0.1	6/30/2018	ATL	2383	PCBs	ND	EPA 505	0.5	0.1	7/5/2018	ATL
2037	Simazine	ND	EPA 525.2	4.0	0.15	7/17/2018	ATL	2326	Pentachlorophenol	ND	EPA 515.4	1	0.04	6/30/2018	ATL
2036	Oxamyl	ND	EPA 531.2	200	4	7/17/2018	RG	2306	Benzo(a)pyrene	ND	EPA 525.2	0.2	0.02	7/17/2018	ATL
2035	Di(2-ethylhexyl)adipate	ND	EPA 525.2	400	0.2	7/17/2018	ATL	2039	Di(2-ethylhexyl)phthalate	ND	EPA 525.2	6.0	0.6	7/17/2018	ATL
2034	Glyphosate	ND	EPA 547	700	10	6/25/2018	RG	2274	Hexachlorobenzene	ND	EPA 525.2	1.0	0.2	7/17/2018	ATL
2033	Endosulfan	ND	EPA 548.1	100	10	6/29/2018	CG	2110	2,4,5-TP	ND	EPA 515.4	50	0.2	6/30/2018	ATL
2032	Diquat	ND	EPA 548.2	20	0.8	6/29/2018	ATL	2105	2,4-D	ND	EPA 515.4	70	0.1	6/30/2018	ATL
2031	Delapron	ND	EPA 515.4	200	1	6/30/2018	ATL	2067	Heptachlor epoxide	ND	EPA 505	0.2	0.02	7/5/2018	ATL
2020	Toxaphene	ND	EPA 505	3.0	1	7/5/2018	ATL	2085	Heptachlor	ND	EPA 505	0.4	0.04	7/5/2018	ATL
2015	Methoxychlor	ND	EPA 505	40.0	0.1	7/5/2018	ATL	2051	Atrazine	ND	EPA 525.2	2.0	0.4	7/17/2018	ATL
2010	Lindane	ND	EPA 505	0.2	0.02	7/5/2018	ATL	2050	Atrazine	ND	EPA 525.2	3.0	0.2	7/17/2018	ATL
2005	Endrin	ND	EPA 505	2.0	0.02	7/5/2018	ATL								

*Reported in ug/L unless otherwise noted
ND = Not detected within sensitivity of instrument (MDL)
-- = No analysis performed
MDL = Method detection limit


Signature of Laboratory Supervisor
Date: 7-26-18

TOM MEHIEL
VALLEY HYDRO INC
1904 E BEECH ST
CALDWELL, ID, 83605

Client Manager: Brian M. McGovern



Analytical Laboratories, Inc.

1804 N. 33rd Street
Boise, Idaho 83703
Phone (208) 342-5515

PDF Only

Email: tom@valleyhydro.com

CC: SWDH; summerwind hoa 1500 w. bannock boise, id 83702

Note: EPA Methods 504.1, 505, 515.4, 525.2, and 549.2 were performed by Anatek Labs (ATL).

Lab Federal ID#: ID00020	Lab Sample 1828648
Date Lab Rec'd Sample: 6/21/2018	Date Reported by Lab: 7/24/2018
Compliance Sample: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Replacement Sample <input type="checkbox"/>
Collection Date: 6/21/2018	Time Collected: 12:00
Sample Type: <input type="checkbox"/> CO-confirmation <input type="checkbox"/> RP-repeat	<input type="checkbox"/> DU-duplicate <input type="checkbox"/> SP-special <input type="checkbox"/> Other
<input checked="" type="checkbox"/> RT-routine	PWS Name: SUMMERWIND
PWS #: 3140220	Tag # / Facility ID:
Sampling Point/Location: SUMMERWIND WELL #1	Contact Phone #: (208) 941-5989
Collector's Name: TOM	

PUBLIC DRINKING WATER SYSTEM RADIOLOGICAL ANALYSIS REPORT

FIDS Number	CONTAMINANT	Result ug/L	Result pCi/L	MCL	Analysis Date	Analyst	Method
4002	Gross Alpha Activity <i>(Includes Radium and Uranium)</i>		--	15 pCi/L			
4006	Uranium, Combined <i>(required if gross alpha exceeds 15 pCi/L; activity = 0.67 x concentration ug/L)</i>	ND	ND	30	6/25/2018	JH	EPA 200.8
4000	Adjusted Gross Alpha <i>(Subtract Uranium activity level from Gross Alpha Activity above)</i>		--				
4020	Radium-226 <i>(Required if Alpha activity is greater than 5pCi/L)</i>		--	5 pCi/L			
4030	Radium-228		--	5 pCi/L			
4010	Total Measured Radium <i>(add results of Ra-226 and Ra-228)</i>		--				
4100	Beta/Photon Activity <i>(Measure major isotopes if activity exceeds 50 pCi/L)</i>		--				

ND = Not detected within sensitivity of instrument
-- = No analysis performed for this contaminant


Lab Supervisor's Signature

Date

Attn: TOM MEHIEL
VALLEY HYDRO INC
1904 E BEECH ST
CALDWELL, ID 83605



Analytical Laboratories, Inc.

1804 N. 33rd Street
Boise, Idaho 83703
Phone (208) 342-5515

PDF Only

Email: tom@valleyhydro.com

CC: SWDH; summerwind hoa 1500 w. bannock boise, id 83702

Note: Radiological testing was performed by Summit Environmental (SUM).

Lab Federal ID#: ID00020	Lab Sample 1828649
Date Lab Rec'd Sample: 6/21/2018	Date Reported by Lab: 7/19/2018
Compliance Sample: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Replacement Sample <input type="checkbox"/>
Collection Date: 6/21/2018	Time Collected: 11:25
Sample Type: <input type="checkbox"/> CO-confirmation <input type="checkbox"/> RP-repeat	<input type="checkbox"/> RT-routine <input type="checkbox"/> DU-duplicate <input type="checkbox"/> SP-special <input type="checkbox"/> Other
PWS #: 3140220	PWS Name: SUMMERWIND
Sampling Point/Location SUMMERWIND WELL #2	Tag # / Facility ID:
Collector's Name: TOM	Contact Phone #: (208) 941-5989

PUBLIC DRINKING WATER SYSTEM RADIOLOGICAL ANALYSIS REPORT

FRDS Number	CONTAMINANT	Result ug/L	Result pCi/L	MCL	Analysis Date	Analyst	Method
4002	Gross Alpha Activity <i>(Includes Radium and Uranium)</i>		ND	15 pCi/L	7/10/2018	SUM	EPA 900.0
4006	Uranium, Combined <i>(required if gross alpha exceeds 15 pCi/L; activity = 0.67 x concentration ug/L)</i>	--	--				
4000	Adjusted Gross Alpha <i>(Subtract Uranium activity level from Gross Alpha Activity above)</i>		--				
4020	Radium-226 <i>(Required if Alpha activity is greater than 5pCi/L)</i>		ND	5 pCi/L	7/12/2018	SUM	EPA 903.0
4030	Radium-228		ND	5 pCi/L	7/11/2018	SUM	EPA 904.0
4010	Total Measured Radium <i>(add results of Ra-226 and Ra-228)</i>		--				
4100	Beta/Photon Activity <i>(Measure major isotopes if activity exceeds 50 pCi/L)</i>		--				

ND = Not detected within sensitivity of instrument
-- = No analysis performed for this contaminant


7-24-18

Lab Supervisor's Signature Date

Attn: TOM MEHIEL
VALLEY HYDRO INC
1904 E BEECH ST
CALDWELL, ID 83605



Analytical Laboratories, Inc.

1804 N. 33rd Street
Boise, Idaho 83703
Phone (208) 342-5515

PDF Only

Email: tom@valleyhydro.com

CC: SWDH; summerwind hoa 1500 w. banmock boise, id 83702


Note: Radiological testing was performed by Summit Environmental (SUM).

Lab Federal ID#: ID00020	Lab Sample 1828650
Date Lab Rec'd Sample: 6/21/2018	Date Reported by Lab: 7/19/2018
Compliance Sample: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Replacement Sample <input type="checkbox"/>
Collection Date: 6/21/2018	Time Collected: 12:00
Sample Type: <input type="checkbox"/> CO-confirmation <input type="checkbox"/> RP-repeat	<input type="checkbox"/> DU-duplicate <input type="checkbox"/> SP-special <input type="checkbox"/> Other
<input checked="" type="checkbox"/> RT-routine	PWS Name: SUMMERWIND
PWS #: 3140220	Tag # / Facility ID:
Sampling Point/Location SUMMERWIND WELL #1	Contact Phone #: (208) 941-5989
Collector's Name: TOM	

PUBLIC DRINKING WATER SYSTEM RADIOLOGICAL ANALYSIS REPORT

FRDS Number	CONTAMINANT	Result ug/L	Result pCi/L	MCL	Analysis Date	Analyst	Method
4002	Gross Alpha Activity <i>(Includes Radium and Uranium)</i>		ND	15 pCi/L	7/10/2018	SUM	EPA 900.0
4006	Uranium, Combined <i>(Required if gross alpha exceeds 15 pCi/L; activity = 0.67 x concentration ug/L)</i>	--	--				
4000	Adjusted Gross Alpha <i>(Subtract Uranium activity level from Gross Alpha Activity above)</i>		--				
4020	Radium-226 <i>(Required if Alpha activity is greater than 5pCi/L)</i>		ND	5 pCi/L	7/12/2018	SUM	EPA 903.0
4030	Radium-228		ND	5 pCi/L	7/16/2018	SUM	EPA 904.0
4010	Total Measured Radium <i>(add results of Ra-226 and Ra-228)</i>		--				
4100	Beta/Photon Activity <i>(Measure major isotopes if activity exceeds 50 pCi/L)</i>		--				

ND = Not detected within sensitivity of instrument
-- = No analysis performed for this contaminant


7-24-18

Lab Supervisor's Signature

Date

Attn: TOM MEHIEL
VALLEY HYDRO INC
1904 E BEECH ST
CALDWELL, ID 83605